

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**

**NEW DELHI- 110001**


No.F6/DFS/MS/School/2021/SZ/ 238

Dated: 19/03/2021

**FIRE SAFETY CERTIFICATE**

Certified that the R.D. International School running at ground & first floor only building comprised of ground plus two upper floors at 297, Nangli Vihar Extn., New Delhi-110043, owned/occupied by R.D. International School was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2016/SZ/174 dated 27/01/2016. The School building was re-inspected by the officer concerned of this department on 12/03/2021 the presence of Mr. Giri Raj (Manager) and found that the School building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 33 of Delhi Fire Service Rules 2010 and that the building/premises is fit for occupancy "Educational Building" for with effect from 19/3/2021 for a period of **three** years, in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 19/3/2021 at New Delhi by

  
(Sunil Chawdhary)  
Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Principal, R.D. International School, 297, Nangli Vihar Extn., New Delhi-110043.
2. Director of Education, GNCT of NCT of Delhi, Old Secretariat, Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.